



太阳能产品认证证书

证书编号: CQC16024142577

申请人名称及地址

深圳古瑞瓦特新能源股份有限公司
深圳市宝安区石岩街道龙腾社区光辉路28号加域工业区办公楼A栋一层东、三层, 厂房B栋

制造商名称及地址

深圳古瑞瓦特新能源股份有限公司
深圳市宝安区石岩街道龙腾社区光辉路28号加域工业区办公楼A栋一层东、三层, 厂房B栋

生产企业名称及地址

深圳古瑞瓦特新能源股份有限公司 (V021430)
深圳市宝安区石岩街道上屋村西边岭加域公司工业区A、B、C栋

产品名称和系列、规格、型号

光伏并网逆变器

Growatt 6000UE : 直流输入:最大功率电压跟踪范围DC200V-800V,最大直流输入电压DC800V,最大输入电流10A; 交流输出:3/N/PE, 230/400V, 50Hz, 8.7A, 额定交流输出功率6kW. Growatt 5000UE : 直流输入:最大功率电压跟踪范围DC200V-800V,最大直流输入电压DC800V,最大输入电流9A; 交流输出:3/N/PE, 230/400V, 50Hz, 7.3A, 额定交流输出功率5kW. Growatt 4000UE : 直流输入:最大功率电压跟踪范围DC200V-800V,最大直流输入电压DC800V,最大输入电流9A; 交流输出:3/N/PE, 230/400V, 50Hz, 5.8A, 额定交流输出功率4kW.

产品标准和技术要求

NB/T 32004-2013 (IIIa, 不含低电压穿越试验)

认证模式

产品型式试验+初次工厂检查+获证后监督

上述产品符合CQC33-461239-2013认证规则的要求, 特发此证。

发证日期: 2016年04月14日

证书有效期内本证书的有效性依据发证机构的定期监督获得保持。



中国质量认证中心

中国·北京·南四环西路188号9区100070

<http://www.cqc.com.cn>

T 0003982



SOLAR PRODUCT CERTIFICATE

No.: CQC16024142577

NAME AND ADDRESS OF THE APPLICANT

Shenzhen Growatt New Energy Technology Co., Ltd.
1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R.China

NAME AND ADDRESS OF THE MANUFACTURER

Shenzhen Growatt New Energy Technology Co., Ltd.
1st East & 3rd Floor of Building A, Building B, Jiayu Industrial Park, #28, GuangHui Road, LongTeng Community, Shiyan Street, Baoan District, Shenzhen, P.R.China

NAME AND ADDRESS OF THE FACTORY

Shenzhen Growatt New Energy Technology Co., Ltd.(V021430)
Building A,B,C, Jiayu Industrial Zone, Xibianling, Shangwu Village, Shiyan, Baoan District, Shenzhen, China

NAME, MODEL AND SPECIFICATION

PV GRID INVERTER

Growatt 6000UE : 直流输入:最大功率电压跟踪范围DC200V-800V,最大直流输入电压DC800V,最大输入电流10A; 交流输出:3/N/PE,230/400V,50Hz,8.7A,额定交流输出功率6kW.

Growatt 5000UE : 直流输入:最大功率电压跟踪范围DC200V-800V,最大直流输入电压DC800V,最大输入电流9A; 交流输出:3/N/PE,230/400V,50Hz,7.3A,额定交流输出功率5kW.

Growatt 4000UE : 直流输入:最大功率电压跟踪范围DC200V-800V,最大直流输入电压DC800V,最大输入电流9A; 交流输出:3/N/PE,230/400V,50Hz,5.8A,额定交流输出功率4kW.

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

NB/T 32004-2013(IIIa,Without Low Voltage Ride Through Test)

CERTIFICATION MODEL

Type Testing of Product + Initial Factory Inspection + Follow up Factory Inspection

This is to certify that the above mentioned products have met the requirements of certification rules CQC33-461239-2013.

President: 

Date of issue: 2016 April 7



Validity of this certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No.188, Nansihuan Xilu, Beijing 100070 P.R.China

<http://www.cqc.com.cn>

T 0003982